Declassified in Part -	Sanitized Cony Anni	roved for Release	<u> </u>	CIA-RDP91-00981R0001	100080004_3
Deciassified III Fait -	Dariitized Copy Appi	Oved for Ivereas	- 2013/03/03 . C		100000004-3
**	', ', ', ', ', ', ', ', ', ', ', ', ', '	0 11 6 1 10 6	IN LEAI.	· ·	U /~ /~~~~~

MC

3 OCT 1988

MEMORANDUM	FOR:	Chief,	Support	Group,	SIO
ED OM .	. [٦.

25X1 FROM:

25X1

25X1

Procurement Executive, OL

SUBJECT:

Proposed Conference Facilities

- 1. In general, your interpretation of our requirements for conference facilities is "on the mark." The proposed configuration of three major conference rooms, which may be used simultaneously for three separate meetings of 30, 40, and 60 conferees respectively, with supporting toilets, lounge, minor office space and security considerations is appropriate to our need. Some detailed comments and requests are listed in the attachment.
- 2. Thanks for sharing your preliminary concepts with us. If you have further questions about our requirements, please contact

Attachment

OL 13178-88 al

CONFIDENTIAL

	Distri Orig 1 1 1	- - -	Addre OL/FM OL Fi OL/FM	G/SPD	REB Cl							
·												
	•							•		•		*
	4			,								
	4				1		•		*			
						•						
						. •				, ,	•	
				·				•		•		
EGIB												

COMMENTS AND REQUESTED FEATURES FOR CONFERENCES

- a) Equip the conference rooms with folding soundproof partitions so they may occasionally be subdivided for small group use.
- b) We understand that the conference room capacities of 30, 40, and 60 are based on using an array of conference tables; however, the capacity using chairs in an audience arrangement could be approximately 45, 60, 90.
- c) HVAC systems should be flexible in cooling capacity to match loads. High volume, low velocity systems with very low noise generation are needed.
 - d) Before plans are crystallized, please review conference room length, width and height ratios, seating patterns, view angles and projection screen size to optimize audience viewing. Technical references in journals and graphic standards recommend the most distant viewers to be a maximum of six screen widths from screen.
 - e) Detailed performance requirements for audio systems should also be determined soon. A recent installation of multiple audio-speakers appears to be very successful.
 - f) Provisions for handicapped employees in conference and dormitory facilities are needed; at this time less than ten percent of our employees are physically handicapped or have severe impairment of sight or hearing that require special consideration.
 - g) In or nearby the lounge, two or three phone niches for use by attendees to contact their offices are desired.
 - h) If possible, locate the kitchen/coffee area of each conference rooms so it is accessible from the corridor.
 - i) We have few comments about the dorm concept or the site work, except to say that a mix of schemes A and B parking may be worth investigating to reduce lot width across the slope and thus ease topographic problems.

25X1

25X1

25X1